

SAS Superstructure

Location: 04-SF-80-13.2 / 13.9 Client Name: CalTrans **Run date** 21-Nov-14 **Time** 11:17 AM

04-0120F4

04-SF-80-13.2/13.9

Self-Anchored

Suspension Bridge

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 155 Const Calendar Day: 356 Date: 30-Aug-2010 Monday Inspector Name: Wilcox, Jason Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 06:30 am 03:00 pm Break: 00:30 Over Time:

Federal ID: Location:

Reviewer: Jefferson, Paul Approved Date: 21-Jan-14 Status: Approved

Weather

 Temperature
 7 AM
 40 - 50
 12 PM
 50 - 60
 4PM
 50 - 60

 Precipitation
 Condition
 Clear

Working Day 🗸 If no, explain:

Diary:

General Comments

FIELD WORK:

See Thanh Le's diary for details on the W-Line and Davdi Bradd's for the E-Line.

- •Performed Post-Arrival inspection of OBG Lift 7E, inside. The exterior was inspected last week. The interior of the OBG has areas where the paint has been scuffed or scratched, but nothing that resulted in significant structural damage.
- •Weld repair continues on both the E-Line and W-Line
- •Welding of the Lifting Lug holes in the Top Deck of Lift 1E continues
- Preparation for the lifting of 7E; position 8E

OFFICE WORK:

- Diary work
- Update progress sheets

Tai-Lin Liu called in sick today.

Accrued 2 hours of overtime today covering the Contractor's hours.